

request for information / addendum 1

project: Fire Department Tower Roof
client: City of Berlin

issued to: All Parties
issue date: 16 November, 2020

The following information constitutes the Request for Information / Addendum 1 for the above referenced project. The information contained herein is supplementary to, and should be read in conjunction with, the Bid Documents identified as Bid Drawings / Bid Specifications dated October 29, 2020.

Responses / Amendments per RFI

Specification Section 07 31 13 – Asphalt Shingle

Amend section 07 31 13 paragraph 1.7.2 to read as follows:

1.7.2 Correct defective work within a **two (2)** year period after Date of Substantial Completion.