

CITY OF BERLIN, NH
GREASE TRAP INSPECTION CHECKLIST

Interior Inspection:

Regular maintenance logs on site
Grease trap < 25% full
Grease interceptor < 25% full
Grease trap inspected by owner every 1 month
Grease interceptor inspected by owner every 3 months
Grease trap and interceptor are accessible
Dishwasher connected to grease trap
Garbage disposal is not connected to grease trap
Toilets and urinals do not connect to grease trap
Fixtures connected to grease trap have flow control valves
Grease trap is as close to fixtures served as practical
Grease trap does not connect to more than 4 fixtures
Fixtures discharging to grease traps are properly strained, trapped and vented
Grease interceptor cover is gas tight
Grease trap is adequately sized (see appendix)

Exterior Inspection:

Outside storage containers are covered
Storage containers are located in berm, containment area or secured.
Storage containers are not located next to catch basins
Spill controls are in place. (i.e. Standard Operating Procedures)
Free flowing absorbent (i.e., kitty litter) is not used